

# Declaration of Performance

## Leistungserklärung



Document No. / Dokumenten Nr.: 10000018193

<b>Products</b> <i>Produkte</i>	RAY158-50CPR, RAYS158-50CPR, RAYA158-50CPR, RLF158-50CPR RLFU158-50CPR, RLK158-50CPR, RLK158-50CPRD, RLKL158-50CPRD, RLKU158-50CPRH	
<b>Identification</b> <i>Identifikation</i>	Product-Name / Batch No. on cable jacket <i>Produktname / Chargen-Nr. auf Mantel</i>	
<b>Intended use</b> <i>Verwendungszweck</i>	Cables in stationery in-building installations are subject to construction products regulation with regards to fire requirements <i>Fest installierte HF-Kabel in Gebäuden unterliegen der Bauprodukteverordnung bezüglich Brandschutz</i>	
<b>Name, registered trademark</b> <i>Registrierter Name</i>	RADIAFLEX® cables <i>Kabel</i>	
<b>Contact Address</b> <i>Kontaktadresse</i>	<b>Radio Frequency Systems GmbH</b> Kabelkamp 20 30179 Hannover Germany	
<b>System of assessment and verification of constancy of performance (AVCP)</b> <i>System zur Bewertung und Überprüfung der Leistungsbeständigkeit</i>	System 1+  This certificate attests that all the provisions concerning the assessment and verification of constancy of performance described in the standard listed below under System 1+ for the performance set out in this certificate are applied and that the factory production control, conducted by the manufacturer, is assessed to ensure the constancy of performance of the construction product. <i>Diese Bescheinigung betätigt, dass alle in der unten aufgeführten Norm unter System 1+ für die in dieser Bescheinigung beschriebene Leistung aufgeführten Bestimmungen hinsichtlich der Bewertung und Überprüfung der Leistungsbeständigkeit Anwendung finden und, dass die vom Hersteller durchgeführte werkseigene Produktionskontrolle so bewertet worden ist, dass sie die Leistungsbeständigkeit für das Produkt sicherstellt.</i>	
<b>Notified Body</b> <i>Benannte Stelle</i>	2851 (CE) 2661 (UKCA)	
<b>Declared Performance:</b> <i>Erklärte Leistung:</i>	<b>Performance</b> <b>Test Standard</b>	
<b>Reaction to Fire</b> <i>Brandverhalten</i>	CPR Classification B2ca s1a d0 a1	EN 50575:2014+A1:2016 (CE) BS EN 50575:2014+A1:2016 (UKCA)
<b>Hazardous Substances</b> <i>Gefährliche Stoffe</i>	none <i>keine</i>	

**We hereby confirm that the products conform to the requirements of the standards / specifications listed.**  
*Wir bestätigen hiermit, dass die Produkte den Anforderungen der Normen / Spezifikationen entsprechen.*

18.04.2024

Robert Zorad, Head of Quality Hannover